

JAIPUR VIDYUT VITARAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (MM)
OLD POWER HOUSE PREMISES, BANI PARK, JAIPUR-302 006.
PH:-0141-2202607/ FAX NO.0141-2202025

NO.JPD/SE/MM/SPO-V/TN-2148/D 2404

DATED : 15/7/11

ADDENDUM/CORRIGENDUM NO. 1**TECHNICAL SPECIFICATIONS FOR PURCHASE OF 200 AMP. L.T.
DISTRIBUTION KIOSKS SUITABLE FOR 63/100 KVA
DISTRIBUTION TRANSFORMERS AGAINST TN-2148.**

The Addendum/Corrigendum in the above technical specification
(Section-III) is issued as under:-

- i) The cross section of the strips appearing in the 4th Para of Clause No. 6
"INCOMER CIRCUIT - ISOLATOR (SWITCH DISCONNECTOR)" may be
read as "30x5 sq. mm" in place of 50x6 Sq.mm"

**(SUNIL MEHTA)**

SUPERINTENDING ENGINEER(MM)

