

JAIPUR VIDYUT VITARAN NIGAM LIMITED  
OFFICE OF THE SUPERINTENDING ENGINEER (MM)  
OLD POWER HOUSE PREMISES, BANI PARK, JAIPUR-302 006.  
PH:-0141-2202607/ FAX NO.0141-2202025

NO.JPD/SE/MM/SPO-V/TN-2121/D 2449 DATED : 19/7/11

**ADDENDUM/CORRIGENDUM NO. 2**


**TECHNICAL SPECIFICATIONS FOR 12 KV OUTDOOR TYPE  
VCB KIOSKS AGAINST TN-2121**

The Addendum/Corrigendum in the above technical specification is issued as under:-

**A) SCHEDULE-III (PART-A)**

- i) The value of One minute power frequency withstand voltage appearing at clause No.4.1.7.2 as 35 kV rms as per IS-3427, may be read as "**35 kV rms**".
- ii) The technical specification of H.T. Trivector Meter, (Section-III Part-B), is hereby revised and attached herewith as Section-III Part-B (Revised).

**Encls.: As above.**

  
**(SUNIL MEHTA)**  
SUPERINTENDING ENGINEER(MM)  
