

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (MM)
OLD POWER HOUSE, NEAR RAM MANDIR, BANI PARK, JAIPUR
PH: 2202607 FAX: 0141- 2202025

Corrigendum

Sub: Amendment in technical specification for supply of 16 KVA Three Phase Aluminium Wound Four star rating Distribution Transformers against TN-2138 due for open on dated 16.05.11

Following amendment in technical specification is hereby made to the extent as indicated below:

Clause No. 14: Heat Dissipation (Cooling): -

The second para of above clause is here by amended to be read as under:

Cooling area of the tank should be sufficient to dissipate the guaranteed losses satisfactorily. Necessary calculations in this regard shall be furnished by the Bidder with their tender. For the purpose of heat dissipation calculations, the following criteria shall be adopted:

Plain surface of tank - 500 W / m²

(Note: The area of top/bottom tank surface, headers, HV/LV bushing pocket and conservator shall not be considered for purpose of above calculations).


(Sunil Mehta)
SUPERINTENDING ENGINEER (MM)