

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (MM)
OLD POWER HOUSE, NEAR RAM MANDIR, BANI PARK, JAIPUR
PH: 2202607 FAX: 0141- 2202025

Corrigendum

Sub: Amendment in technical specification for supply of 16 KVA Three Phase Aluminium Wound Four star rating Distribution Transformers against TN-2138 due for open on dated 16.05.11

Following amendments in technical specification is hereby made to the extent as indicated below:

Clause No. 16 (C): Core Coil Assembly :-

The dimension of Tie rods and core studs, appearing at Sr. No. a) & b) of above clause may be read as 12 mm in place of 10 mm

Clause No. 30 (ii): Air Pressure test :-

The first para of this clause may be read as under :-

"This test shall be conducted as type test at the time of inspection of first lot, at the manufacturer's works. The pressure gauge and vacuum gauge shall be duly calibrated and sealed by an independent recognised test lab(s)."


(Sunil Mehta)
SUPERINTENDING ENGINEER (MM)

