

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (MM)
OLD POWER HOUSE, NEAR RAM MANDIR, BANI PARK, JAIPUR
PH: 2202607 FAX: 0141- 2202025

Corrigendum

Sub: Amendment in Technical Specification for supply of 315/500 KVA Three Phase Copper Wound Distribution Transformers against TN-2143 due for open on dated 20.05.11.

Following amendment in technical specification is hereby made to the extent as indicated below:

Clause No. 30: ROUTINE/ ACCEPTANCE TESTS:

The para "**Following tests shall also be carried out at manufacturer's works on one complete unit of 160 KVA Transformers unit. These tests shall be got conducted/ witnessed by the inspecting officer of independent NABL accredited lab and the certificate shall be issued by the same lab**" of above clause is hereby amended to be read as under:

"Following tests shall also be carried out at manufacturer's works on one complete unit of 160 KVA Transformers unit."


(SUNIL MEHTA)

SUPERINTENDING ENGINEER (MM)

