

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (MM)
OLD POWER HOUSE PREMISES, BANI PARK, JAIPUR.
 TELEPHONE: 0141-2202607 / FAX:- 0141-2202025
SPECIFICATION NO.JPD/SE/MM/TN-2149

THREE PHASE, FOUR WIRE, 10-60 AMP. RATING, WHOLE CURRENT, CLASS 1.0 ACCURACY KWh ENERGY METERS WITH BACKLIT LCD DISPLAY WITHOUT METER CUPBOARD

Last date for receipt of tenders	08.11 .2011 upto 2:30 PM
Date & time of tender opening	08.11 .2011 at 3:00 PM
Cost of Specification	Rs. 2,500.00 per set
Validity of tenders required upto	120 days after the date of opening of tender.
Earnest money to be deposited	Rs. Seven Lac Fifty Thousand / Exemption Certificate or vendor registration of category class `A` .

FOR SUPERINTENDING ENGINEER(MM)

IMPORTANT NOTE:

1. Earnest Money as per clause No. 1.03 of section-I of this specification or vendor's registration with JAIPUR DISCOM under category `A` or above as per clause 1.5.3 of GCC and cost of Bid document as per clause No. 1.02.9 of section –I **“Instructions to Bidders”**.
2. The Central and State Govt. undertaking shall be exempted from furnishing of earnest money deposit provided that they furnish a certificate / documentary evidence in support of their being Govt. (Central/State) undertaking.
3. **The tender enclosing all schedules III to IX duly completed should be furnished as per section-I “Instructions to Bidders” of this specification.**
4. The technical deviations including GTP and commercial deviations, if any, shall invariably be stated in Schedule-VI (A & B) Departure from specifications attached with this specification. **Mentioning of such deviations elsewhere will not be considered. The standard printed conditions of sales and other if any attached with the tender will not be considered.**
5. The prices offered against this specification shall be FIRM.

SCHEDULE-III-A**QUALIFICATION REQUIREMENT**

ITEM:- THREE PHASE A.C. STATIC ENERGY METER OF RATING 10-60 AMP. OF ACCURACY CLASS 1.0 WITH OPTICAL PORT AND LOW POWER RADIO COMMUNICATION FACILITY WITH BACKLIT LCD DISPLAY.

TN-2149

The bidder should fulfil following qualifying requirements for successful participation in the tender along with relevant documentary evidence supporting each qualifying requirement without which the offer shall be considered non-responsive & rejected.

- I) The bidder should be a Manufacturer of offered items. The offers from Sole Distributor / Sole Selling Agent / Authorized Dealer shall not be entertained.
- II) The bidder shall have BIS Certification for offered rating of meters as on date of bid opening. Bidder shall have to furnish the notarized copy of ISI License along with the bid.
- III) The bidder is required to quote for minimum 3.33% of tendered quantity, failing which the offer may be considered Non-Responsive.
- IV) The bidder should have designed, manufactured / fabricated, tested and supplied to utility / Discoms / Govt. Departments at least 2XQQ (QQ being the quoted quantity) of Three Phase Static Energy Meters in last three years from the date of opening of technical-commercial bid. In support of fulfillment of the past supply criteria, the bidder shall furnish documentary evidence in the form of certificate from Chartered Accountant in the prescribed proforma only. This prescribed proforma should be either in original or copy duly attested by Notary. The bidder shall also sign and affix seal on the prescribed format C.A. Certificate. The certificate should have membership number with the name & address of the chartered accountant. Certificate should clearly indicate the quantity supplied, period of supply, voltage class / accuracy class of the material etc. in the format prescribed any deviation to format or information diverted format, will not be considered and rejected.
- V) The bidder shall furnish valid and authenticated type test certificates from a Govt. approved / a Govt. recognized / NABL Accredited laboratory / ILAC i.e. International Laboratory Accredited Laboratory / ILAC i.e. International Laboratory Accreditation Cooperation (in case of foreign laboratory) of similar rating and design of tendered material / equipment. Such type test certificates should not be older than 2 years as on the date of bid opening. For this purpose date of conducting type test will be considered. The type test certificate by in house laboratory of tendering firm even if it is a Govt. approved / Govt. recognized / NABL accredited / ILAC accredited, shall not be accepted, in case of their own tender. This will not apply if tendering firm is Govt. company / public Sector undertaking.

The bidder should furnish documentary evidence in support of the laboratory whose type test have been furnished, that the said laboratory is a Govt. / a Govt. approved / a Govt. recognized / NABL accredited laboratory / ILAC accredited (in case of foreign laboratory).

The type test certificates shall be furnished either in original or copy duly attested by notary.

The bids of only those bidders shall be considered to be meeting the type test criteria who furnishes complete type test certificate with the bid as per above provision.

- VI) The bidder should possess adequate testing facilities for carrying out routine & acceptance test of items as per relevant standard at their works. The bidder shall furnish documentary evidence in support for conducting routine & acceptance test.
- VII) (a) Samples along with bid – The bidder shall furnish Four meters conforming to this specification duly sealed along with the routine test certificates along with the bid. If the samples are not received with the bid, the bid shall be considered as Non-responsive. Out of the above four sample meters, three sample meters shall be tested at any NABL accredited independent test lab in presence of firm's representative. The testing charges shall be borne by the bidder. One sample meter shall be checked / tested for mechanical/physical features in Nigam's Lab. In case sample meters submitted with bid don't conform the type tests, additional type tests & tamper tests as per the requirements of specifications/IS, the financial bid of offer shall not be opened. The tentative testing charges Rs. 2.0 lac shall be deposited by bidder in the form of Demand Draft in favor of the Account Officer (MM), Jaipur Discom, Jaipur.
- The bidder shall furnish BG / DD / Pay Order for Rs.5 Lac and undertaking that in case an order is awarded, the samples before commencement of supply shall be furnished conforming fully to the requirement of this specification. In case the bidder fails to furnish sample conforming to our specification before commencement of supplies their Bank Guarantee / DD / Pay Order will be invoked / forfeited (Proforma for submitting undertaking a Bank Guarantee is enclosed at Schedule-IIIB). The initial validity of B.G. shall be nine months.
- VIII) The bidder shall clearly indicate the deviations such as Technical Deviation & Commercial Deviations in the prescribed proforma only. The deviations indicated elsewhere in the bid shall not be accepted.
- IX) The bidder must clearly fill up each and every particular of Guaranteed Technical Particulars annexed with Technical Specification otherwise he will be responsible for Technical Non-Responsiveness.
- X) The bidder shall possess fully / semi-automatic computerized meter testing system with printer and static source and duly calibrated Electronic Reference Standard (ERS) meter of Class 0.1 Accuracy or better.

Note :

- i) Rajasthan based firms not meeting minimum quantity supplied criterion but having manufacturing and adequate testing facility and technical know how shall be considered as new firms and would be eligible for trial order only.
- ii) Requirement of quantity manufactured, minimum quantity to be offered and amount of Bank Guarantee to be furnished shall be reduced to 25% for Rajasthan based units.

TECHNICAL SPECIFICATION FOR A.C. STATIC THREE PHASE, FOUR WIRE, 10-60A RATING WHOLE CURRENT, CLASS 1.0 ACCURACY, KWH ENERGY METERS WITH OPTICAL PORT AND LOW POWER RADIO COMMUNICATION FACILITY AND BACKLIT LCD DISPLAY AGAINST TN-2149.

1.0 SCOPE

- a) This specification covers the design, engineering, manufacture, assembly stage-testing, inspection and testing before supply of A.C. three phase, four wire, whole current static energy meters of accuracy class 1.0 and current rating 10-60 Amps, with backlit LCD display as per requirement given in this specification. The meter shall be supplied in suitable packing so as to withstand transit shock.

The three phase, four wire, three element type meter should be capable to record and display energy in kWh, demand in kW and power factor for three phase four wire A.C balanced / unbalanced loads for power factor range of zero lag – unity zero lead, as per requirement given in this specification.

- b) It is not the intent to specify completely herein all the details of the design and construction of material. However the material shall conform in all respects of high standards of engineering, design and workmanship and shall be capable of performing in continuous commercial operation in a manner acceptable to the purchaser, who will interpret the meanings of drawings and specification and shall have the right to reject any work or material which in his judgment is not in accordance therewith. The offered materials shall be complete with all components, accessories necessary for their effective and trouble free operation of the system for energy measurement. Such components shall be deemed to be within the scope of Bidder's supply irrespective of whether those are specifically brought out in this specification and / or the commercial order or not.

The offered meters shall have BIS certification i.e. the offered meters shall be ISI marked and bidder shall have to furnish the notarized ISI license as on date of bid opening.

2.0 REQUIREMENT:

The requirement of 3 x 240 Volt 50 Hz A.C. Static Three Phase 10-60 Amp. rating whole current Energy Meters of accuracy class 1.0 with optical port and Low Power Radio communication facility is as under:

1. For Jaipur Discom – 1,66,000 Nos.
 2. For Ajmer Discom – 70,000 Nos.
 3. For Jodhpur Discom – 14,000 Nos.
- Total- 2,50,000 Nos.

3.0 STANDARDS APLICABLE :

Unless otherwise specified elsewhere in this specification, the meter(s) shall conform in all respects including performance and testing thereof to the following Indian / International Standards to be read with upto-date and latest amendments / revisions thereof.

S.No.	Standard No.	Title
1.	IS:13779-1999 (with latest amendments)	Specification for AC static watt hour meters Class 1 & 2

- | | | |
|----|---|--|
| 2. | IEC 62052-11 | Electricity metering equipments (AC) – General requirements & test conditions Part 11. metering equipments |
| 3. | IEC 62053-21 | Electricity Metering equipments (AC)-particular Requirements – Part – 21 Static meters for active Energy (class 1 & 2) |
| 4. | IEC – 61000-4-5 (2001-04) | Electromagnetic capability, Testing and measurement Techniques, Surge immunity test |
| 5. | IEC 61358:1996 | Acceptance inspection for direct connected AC static Watt hour meter for active energy (class 1 & 2) |
| 6. | Central Board of Irrigation and Power New Delhi technical Report No. 304 read with latest amendments issued till date | Specification for AC static electrical energy meters. |
| 7. | IS : 9000 | Basic Environmental testing Procedures for Electronic & Electrical items. |
| 8. | IEC 62053-61 | Electricity Metering Equipment (a.c)- Particular requirement- Part- 61 – Power consumption and voltage requirements |
| 9. | IEC-62056-21 (Latest Version) | Data exchange for meter reading and direct local data exchange. |
| 10 | IEC – 15707 , 2006 | Testing Evaluation, Installation and Maintenance of A.C. Electricity Meters. CODE OF PRACTICE. |
| 11 | IS:12346(1988) | Specification for testing equipment for AC Electrical energy meter |
| 12 | CEA Regulation | On installation and operation of meters dated 17.03.2006. |
| 13 | RERC Regulation | On installation and operation of meters 29.5.2007. |

In case of any conflict or discrepancy the order of precedence shall be (i) IS (ii) IEC (iii) CBIP technical report-304 (read with latest amendments). In case of any difference between the provisions of these standards and the provisions of this specification, the provisions contained in this specification shall prevail.

4.0 **SERVICE CONDITIONS (CLIMATIC CONDITIONS)**

The meters to be supplied against this specification should be capable of performing and maintaining required accuracy under extreme hot, cold, tropical and dusty climate and solar radiation typically existing in state of Rajasthan (India). The meter shall be required to operate satisfactorily and continuously under the following tropical climatic conditions.

a.	Maximum ambient air temperature	55 deg.C
b.	Maximum ambient air temperature in shade	45 deg.C
c.	Maximum temperature attainable by the meter exposed to sun	60 deg. C
d.	Minimum ambient temperature	(-) 5 deg.C
e.	Average daily ambient air temperature	40 deg.C
f.	Maximum relative humidity	95 %
g.	Number of months of tropical monsoon condition	4 months
h.	Maximum altitude above mean sea level	1000 meters
i.	Average annual rain fall	10-100 cm
j.	Maximum wind pressure	200 kg/sq.m
k.	Isoceraunic level (days per year)	40
l.	Seismic level (horizontal accn.)	0.30 g
m.	Permitted noise level	45 db

5.0 **Principal Parameters**

The meter shall conform to following parameters

<u>S.No</u>	<u>Item</u>	<u>Specification</u>
1.	Type of installation	Outdoor installation inside box
2.	System Voltage	3x240 V, -40% to +20%
3.	System frequency	50 Hz \pm 5%
4.	No. of phases	Three phase four wire
5.	System of earthing	Solidly grounded

6.0 **Technical Requirements**

a.	Rated voltage (Vref)	3X240 V phase to neutral, (3phase 4wire system) 3X415 V phase to phase
----	----------------------	---

- b. Rated current Basic current 10A (I_b), Max. current 60A (I_{max})

6.1 Supply System & Power Supply Variation

The supply system shall be LT 240 volts phase to neutral, three phase four wire.

The extreme power supply variation for which an operating meter should withstand without damage and without degradation of its metrological characteristics when it is subsequently operated under its normal operating conditions shall be as follows.

Specified operating range 0.80 to 1.1V_{ref}

Limit range of operation 0.60 to 1.2 V_{ref}. However, the bidder can offer meters which can withstand higher variations.

The limits of error for +20% to -40% V_{ref}. variation shall be as under:

Influence quantities		Value of current	Power factor	Limits of variation in % error
i)	Voltage variation between -40% to +20%	I _b I _b	1 0.5 lag	0.7 1.0
ii)	10% of 3 rd harmonic in current circuit	0.6 I _b 0.6I _{max}	UPF UPF	0.6 0.6

- 6.2 The meter shall be functional & able to register energy even if the voltage falls up to **60%** of the rated voltage **i.e. 96 Volts and 500 mili Amps.** at balance load conditions (No accuracy is required).

Power Factor Range

The meter shall be suitable for full power factor range from zero (lagging) through unity to zero (leading)

6.3 Accuracy

Class of Accuracy of the meter shall be 1.0. The accuracy should not drift with time.

6.4 Power Consumption

- a. Voltage circuit: The active and apparent power consumption in each voltage circuit including the power supply of meter at reference voltage reference frequency and reference temp. shall not exceed 1.0 watt per phase and 8 VA per phase respectively **on balance load condition.**
- b. Current circuit: The apparent power taken by each current circuit at basic current, reference frequency and reference temp. shall not exceed 0.5 VA.

6.5 Starting Current

Meter should start registering the energy at 0.2% I_b at UPF in each phase.

6.6 **Running with No – Load**

When 70% and 120% of rated voltage is applied with no current flowing in current circuit, the test output of the meter shall not produce more than one pulse / count. The minimum test period for this test shall be as per relevant clause 8.3.2 of IEC 62053-21-2003.

6.7 **Auxiliary Power**

The power shall be drawn from any of three phases and the meter should be able to remain powered up if any two phases or any one phase and neutral are available.

7.0 **General and Constructional Requirements**

Meter shall be designed and constructed in such a way so as to avoid causing any danger during use and under normal conditions. The following should be ensured

- 1 Personnel safety against electric shock.
- 2 Personnel safety against effects of excessive temperature.
- 3 Protection against spread of fire.
- 4 Protection against penetration of solid objects, dust and water
- 5 Protection against fraud
- 6 Prevention against pilferage

7.1 **Meter Case**

- a. Meter case (base and cover) and extended terminal block cover (ETBC) shall be made of unbreakable high grade flame retardant poly carbonate of good dielectric and mechanical strength with minimum thickness of 2.0 mm, however, due to manufacturing process, the negative tolerance of 0.2 mm may be allowed.
- b. Meter case (base and cover) and extended terminal block cover (ETBC) should be injection moulded in UV stabilized poly-carbonate. The base of meter shall be of any colour & cover shall be transparent easy to reading of all the displayed values/ parameters, nameplate details and calibrating LED. The ETBC shall also be kept fully transparent. The moulded meter case should not change in colour, shape, size, dimensions when subjected to 200 hrs on UV test as per ASTM D 53. It should withstand 650 deg. C. glow wire test and heat deflection test as per ISO 75.

- c. The manufacturer shall emboss on the base/cover the name of the material they have used in an abbreviated form e.g. PCFR (to denote what they have used - flame retardant poly carbonate).
- d. The meter cover shall be permanently fixed to the base by heat staking / ultrasonic welding in such a manner that cover can not be opened without breaking i.e. the meter should be break to open type. The meter base and top shall have distinct contour to identify, if any tampering attempt has been made or opening of cover with some tool or by using hot wire or similar device. In case any attempt to open the meter cover from base, there should be visible evidence of opening / tampering of ultrasonic welding.
- f. The meter case shall have the following properties of plastic material

<u>S.No.</u>	<u>Property</u>	<u>Units</u>	<u>Value</u>	<u>Standards</u>
1	Physical water absorption	%	Max. 0.35	ASTMD 570/ IS:5133(part 2) :1969
2	Electrical Dielectric strength at 90 deg. C. in oil.	KV/ MM	Min 16	ASTMD 149
3	Thermal HDT	Deg.C	Min. 125	ASTMD 648/ ISO 75
4	Flammability			
	a) Rating		FV 2	UL94/ IS:11000(part 2-sec-1)
	b) Glow wire test 650 deg.C.		Passes	IEC-60695-2-1-12 & IS:11000-2-1
	Mechanical			
	a) Tensile strength	MPa	Min. 50	ISO 527 / any equivalent standard
	b) Flexural strength	MPa	Min. 90	ISO 178 / any equivalent standard
	c) Modulus of Elasticity	MPa	Min.	ISO 178 / any equivalent standard
	d) Izod impact strength notched 23 Deg. C.	KJ/ Sq.M	2000 Min. 8	ISO 180/1A or any equivalent standard

7.2 **Terminal block, Terminal and Extended Terminal Block cover**

1. The terminal block shall be moulded type made of non-hygroscopic, flame-retardant material having good dielectric and mechanical strength. The moulded terminal block shall be made from best quality phenol formaldehyde conforming to IS:13779 -1999 (latest amended) having adequate insulating properties and mechanical strength with brass inserts for connecting terminals.
2. The terminal block should satisfy all the conditions specified in IS:13779 and IEC 62052 - 11. The material of the terminal block should fulfill the requirement of following tests
 1. The flame retardant rating of V0 as per UL 94 testing
 2. The glow wire test for temperature of 960 deg. C as per IS:11000 (Part -2/Sec.1) or IEC 60695-2-1
 3. Heat deflection temperature (HDT) test of 135 deg. C. as per ISO 75 or ASTM D-648
 4. Ball pressure test at 125 deg. C. as per IEC 60335-1
3. The base of the meter should extend to enclose the three sides (back and two sides) of the terminal block.
4. The current circuit conductors of the meter shall be connected to its current terminals from inside the meter terminal block adopting procedure prescribed in either B-1 or B-2 of the recommended methods under IS:13779. Any other method which meets these requirements in a better manner/way shall also be considered. The bidder should elaborate the arrangement adopted.
5. The meter terminal block shall have tin-plated brass terminal inserts. The terminals shall have suitable construction with barriers and cover to provide firm and safe connections of incoming and outgoing leads. The terminal screws shall have flat bottom so as not to pierce in the external conductors. The terminals shall be of suitable rating to carry continuously 150% I_{max}. Current and made of electroplated (or tinned) brass. Any other provision which meets this in a better manner / way shall also be considered. The bidder should elaborate the provision adopted.

6. The manner of fixing the external conductors to the terminal block shall ensure adequate and durable contact such that there is no risk of loosening or undue heating. All parts of each terminal shall be such that the risk of corrosion is minimized. Two screws shall be provided in each incoming and outgoing terminal for effectively clamping the external leads. Each screw shall engage at least 3 threads in the terminal. Electrical connections shall be so designed that contact pressure is not transmitted through insulating material. The manner of fixing of incoming and outgoing leads into the terminals shall be through thimbles/lugs/reducer type terminals and the supplier shall supply the same alongwith each meter without any extra cost.
7. The internal diameter of the terminal holes should be not less than 9.5 mm and adequately designed for inserting 6 mm² to 25 mm² stranded copper/aluminum armoured PVC cable and shall be capable of carrying continuous current up to 150% of I_{max}. The holes in the insulation material of the terminal block, which form an extension of the terminal holes, shall be of sufficient size to accommodate the insulation of the conductors also. The clearance and creepage distances shall not be less than values specified in clause 6.6. of IS:13779:1999. Further, the supporting webs between the two terminals of the terminal block should be sufficiently high to ensure that the two neighboring terminals do not get bridged by dust or a flash over does not take place.
8. The voltage circuit and the current circuit shall be solidly connected inside the meter body without any link. A firm connection shall be established within the meter case to energize the voltage circuit.

9. The termination of current circuit wires, if used, inside the meter (i.e. CT primary conductor / shunt) on the terminal block should be through lugs and washers of proper size. The shunt used shall be high precision, low temperature coefficient, high stability of electric resistance, low watt loss and are magnetically tamper proof. The loop length of the primary current circuit should be kept minimum. Alternatively the CT primary conductor / shunt may be flattened to form a 'lug' like shape for proper terminating on terminal block without using lug or any other better arrangement may also be provided.
10.
 - i) The meter shall be supplied with extended terminal block cover (ETBC). The ETBC shall be extended by minimum 50mm below the terminal block with suitable sealing arrangement of terminal cover for providing numbered double anchor polycarbonate lash wire seal, which shall be supplied loose by the bidder as per the Tech. Spec. of Polycarbonate Seal.
 - ii) The ETBC shall be designed such that the meter's internal parts are not accessible for tempering etc. without breaking seals.
 - iii) Suitable barriers in moulding shall be provided such that direct access to incoming/outgoing terminals is not possible through gaps left in cable entry holes after insertion of main/load side cables
 - iv) The terminal cover shall be engraved/ Laser marked with logo of manufacturer & purchaser i.e. JVVNL.
 - v) The terminal cover of the meter should be hinged either at the top so that it opens from bottom to top or hinged at the left side so that it opens from right to left of the meter.

7.3 Display Parameters and Type of Display:

- A)** The meter should have bright LCD electronic display with backlit having minimum description of parameters (e.g. words like kwh, Kw, Power factor etc)/ legends (alphabets) height X width of 5mmx3mm minimum and with minimum **6** digits (numerals) of size 10mmX5mm in auto scroll mode. **The decimal digit shall be of smaller but not less than 5 mm X 3 mm and shall be clearly distinguished from integral digits or if the digits size is same then the decimal digit shall be clearly distinguished from the integral digits.**

The LCD shall be of STN (Super Tested Kneumatics) or FSTN type, construction suitable for temperature withstand of 80 deg. C (storage) and 65 deg. C (operation). The LCD Display should have a wide viewing angle of 45 deg to 60 deg cone, up to one metre distance.

LCD Specifications:

Type: STN, FSTN, Seven segment type, Industrial Grade

Viewing angle: 6 0 clock

Background type: Yellow/Green/Grey/white

Connector: Pin Type

Polarizer mode: Transreflective/transmissive

Segment Colour: Black/Dark Blue

Life time: 100k Hours

Temp range Operative: - 20 to 65 deg. C.

Temp range Storage: - 40 to 80 deg. C.

Voltage: 3.0/5.0V

Drive method: 1/4 / 1/3 bias

Testing: High temp test as per specs for 72 Hrs

Low temp test as per specs for 72 Hrs

Result: After test the LCD should not get damaged.

Temperature Shock Test: 10 cycles temperature shock of low and high temperature.

The registered parameter shall not be affected by loss of power. The display shall not be affected by electrical & Mechanical disturbances. The Non-volatile Memory (NVM) shall have a minimum retention time of 12 years under un-powered condition i.e. the NVM shall have a storage life (without use) of 12 years. The battery back-up memory will not be considered as NVM. All important data such as calibration data, billing parameters and cumulative kWh should be stored in NVM internal to the main processing circuit and it should not be possible to change the data through any standard serial communication.

For clear visibility of the display of the meter reading at a distance, large viewing area with large display icons is preferred.

When the meter is placed in oven at a constant temperature of 65°C for period of 120 minutes, the character of LCD should not deform.

After keeping the meter at a constant temperature of 80°C for period of 120 minutes and when restored at normal temperature, the LCD should work satisfactorily.

The meter shall be capable to measure & display continuously 'Active energy KWH' at all the loads & power factors i.e. Zero lag – Unity – zero lead. The meter should also have provision for Automatic recording of cumulative kWh at 24.00 Hrs on the last day of the month for each calendar month & the same should go to memory.

B) The accuracy of display parameters on LCD display for all parameters shall be matching with the accuracy Class of the meters as per IS, if not specifically mentioned elsewhere in this specification. This shall be verified during inspection/ testing of meters.

The display of various parameters in push button mode shall be scrolling one after another. The meter shall be capable to measure and display continuously "Active Energy KWh" at all loads and power factors i.e. Zero lag-Unity-zero lead.

Meter Data Display : The software shall show electrical condition existing at the time of reading the meter in tabular forms as well as graphical format (phase diagram) at BCS end.

C). Display Sequence:

The meter shall display the required parameters in two different modes as follows:

a) Continuous display:

Current cumulative active forwarded energy (Total Energy) without decimal shall be continuously displayed.

b) Push Button display:

The following parameters shall be displayed one after other, with press of push button each time. The display shall have on time of approx. 10 seconds for each measured values, except the LCD Segment Check, with shall have display of 2 Seconds. If the Push Button is pressed continuously for 5 minutes then battery should become disabled.

1. LCD Segment Check.
2. S.No. of Meter.
3. Date and Time.
4. Current Cumulative active forward Energy (Total) with one decimal.
5. Cumulative active energy (KWh forwarded) reading of pre-defined date & time of previous month for Billing purpose (BP kWh), 6 whole digits.
6. Maximum demand (KW) of pre-defined date & time of previous month for billing purpose (BP KW), 2 whole digits plus 2 decimal digits.
7. Average power factor up to pre-defined date & time of previous month for billing purpose (BP Ave PF), one whole digit plus 3 decimal digits.
8. Instantaneous active load in KW with three decimals.
9. Instantaneous Voltage per phase with one decimal.
10. Instantaneous current per phase with two decimals.
11. Signed Instantaneous Avg. Power factor with three decimals.

D) LCD least count

The internal least count of energy recording shall not be more than 0.01kWh. Hence, every 0.01 kWh consumption will be internally stored. Also, there be no loss of energy registration on account of frequent power outages due to high start up time of the meter.

To verify the above, the meter will be switched ON/OFF 40 times at rated parameters and energy recording on display with decimal digit should be within 0.4 kWh of the energy, it should register, as per its accuracy at that load. This will be verified during inspection of meters.

E) Meter Reading at Power Outage:

Provision to read the meter in no power condition for displaying the push button parameters shall be made. Such provision shall be provided in the form of Push Button activated Primary/Rechargeable Battery.

No Power shall be consumed from this circuit when mains are available. In any case, RTC battery power shall not be used for display under power off conditions.

F). TIME OF DAY TARIFF:

The meter shall have provision for registering energy, maximum Demand and average PF in following five tariff registers:-

05.00 Hrs. to 06.00 Hrs.

06.00 Hrs. to 09.00 Hrs.

09.00 Hrs. to 18.00 Hrs.

18.00 Hrs. to 23.00 Hrs.

23.00 Hrs. to 05.00 Hrs.

This data for the last **12 months** shall be download by CMRI.

G). MAXIMUM DEMAND REGISTRATION AND MD RESETS :

Meter shall continuously monitor and calculate the average maximum demand of each demand interval time of 30 minutes and maximum of these in a calendar month shall be stored. The maximum demand shall automatically reset at 24.00 hrs. of the last date of each calendar month for which minimum 30 years calendar shall be programmed by the manufacturer. The cumulative kWh should also be recorded at 24.00 hrs. on the last date of each calendar month for previous **twelve** months.

H). DISPLAY IN POWER OUTAGE :

Provisions to read the meter in no power condition for displaying the auto scroll mode parameters without push button shall be made through rechargeable battery.

Under no power condition when the meter is powered through Battery, Back-Lit of LCD is not required.

In any case, RTC battery power shall not be used for display under power off condition.

7.4 OUTPUT DEVICE

The meter shall have a test output device in the form of calibration LED of red colour and minimum intensity 10 m CD (milli-Candela) accessible from the front and shall be capable of being monitored conveniently with suitable testing equipment while in operation at site. The location of calibration LED should be such that the calibration pulses can be sensed easily through the sensor. The clearance of calibration LED from any of the sides of window portion shall be approximately 20 mm.

The relation between test output and the indication on display shall comply with the marking on the name plate (impulse per kwh).

The bidder shall state the necessary number of pulse count(s) to ensure measurement accuracy of at least 1/10th of class of the meter at the different test points.

The resolution of the test output pulse(s) should be sufficient to enable conduction of the starting current in less than 10 minutes and accuracy test at the lowest load with desired accuracy within 5 minutes.

7.5 COMMUNICATION CAPABILITY: Meter Shall have Optical communication Port as well as Low Power Radio communication for facility of meter reading.

(A) Optical Communication Port :

The meters shall have a galvanically isolated optical communication Port as per IEC1107 provided on the front of the meter downloading the history data to a CMRI/Base computer. It shall not be possible to re-programme or make any change in the meter through CMRI.

- No editing shall be possible on CMRI and base computer by any means. The software shall have capability to convert the entire data into ASCII format.
- The protocol used in the meter shall have to be provided at the time of supply for the purpose of automatic meter reading system.
- It shall be responsibility of the meter manufacturer to provide the required software and all the facilities free of cost to enable the use of optical port and LPR Communication facility for reading and retrieving the data from the meter through CMRI and to necessary upgrades of software shall be supplied free of cost for downloading simultaneously the existing parameters and any parameters added in future specifications of meters.

- Indication on CMRI shall be provided for confirmation of successful data transfer from meter to CMRI. During this period the energy recording should not be affected.

The offered common meter reading instrument should work as a **one**_way communicating interface between various make static energy meters and a base computer station for the purpose of exchange of data. The meter Reading instrument shall be supplied with necessary accessories which should be capable of interrogating with various makes of AC static energy meters when loaded with the corresponding meter's specific software called meter reading instrument programme.

It shall be responsibility of the meter manufacturer to provide the required software and all the facilities required by JVVNL to use the CMRI for reading and retrieving the data from the meter and to download the data to PC free of cost up to guarantee period.

Readings to be downloaded with CMRI:

In addition to all the above, the following parameters should be downloaded by CMRI

- Meter Sr. No.
- Time & Date.
- Instant Load in KW, Voltage, Current & Power Factor
- Billing kWh (BP kWh) for the last **12** months at 0:00 hrs of the last day of the month.
- MD KW with 30 min. integration on real time basis for each phase with date and time stamp for the last **12** months.
- Average power factor of the last consumption month upto pre-defined date & time for the last **12** months.
- Power on Hours and minutes for each of previous **12** months
- The snap shot of each event with date & time of minimum 40 events(either occurrence or restoration consider an event) for following tamper condition:
 - (i) The tamper data as per Cl. 7.6 (c) & (g) of this specification
- Any other information if manufacturer proposes may indicate in their offer.

Any other information if manufacturer proposes may indicate in their offer.

The meter shall also have a storage capacity for at least 60 days in the non-volatile memory for recording, logging, and downloading of Power On hours per day and kWh consumed for each day starting from 00.00 to 24.00 hours. Such data shall be made available in the form of bar chart as well as spreadsheet. The BCS shall have

the facility to give complete load survey data both in numeric and graphic form with option for either of them.

The meter shall possess a suitable fast reliable **optical communication port as well as LPR communication Port** for automatic transfer of data to CMRI and through CMRI to the base computer.

The CMRI shall possess easily replaceable battery and shall be capable of storing data for at least 200 Nos. meters at one time. It shall be possible to read the meter from outside the meter box. The data transfer (from meter to CMRI) rate of billing data downloading shall be 60 Seconds and for total data within 5 minutes for each meter.

The downloaded data along with date and time stamp of such reading shall remain on CMRI with suitable encryption and it shall not be possible to preprogram or manipulate the recorded data on the CMRI before downloading the same with the serial number of CMRI on computer. The CMRI shall also download the name of meter manufacturer and year and month of manufacture of meter. The Supplier shall supply Software (compatible with Windows 98 system or higher) and training free of cost for the use of software at multiple data collection and billing premises of the utility. The CMRI shall have a polling feature to read multiple meters within range without preprogramming the meter serial numbers on CMRI in advance.

After successful downloading of meters data to CMRI, the calibration LED shall continuously glow for a period of one minute/ any other indication on CMRI for confirmation of successful data transfer. During this period the energy recording should not be affected.

Necessary upgrades shall be possible in CMRI software and shall be supplied free of cost for downloading simultaneously the existing parameters and any parameters added in future specifications of meters. A copy of operation manual for each CMRI shall be supplied.

The Supplier shall provide meter reading protocols free of cost which shall not be complicated and easily understandable by utility officials to introduce compatibility between meters and CMRIs of different makes.

The bidder shall indicate relevant standard to which the protocol for communication between meter and CMRI shall comply.

(B) Low Power Radio Communication Facility:

The meter reading instrument shall be capable of retrieving data and capable of transferring them to the base computer service center for energy audit and billing purpose. The tenderer shall quote for the 10-60 Amp. meters with LCD Display with communication facility for meter reading with Low Power Radio (LPR) Communication Facility. The meter shall be compatible for spot billing. The meter shall have facility for communicating with a Meter reading instrument through LPR with proper security & without error to facilitate for auto-reading and downloading the billing and history data to

base computer. The LPR shall be provided on the meter cover. Tamper proof arrangement shall be made to get the reading of meter data even at the time of power failure, without use of external battery. The interface for communication between CMRI & Base computer shall be supplied free of cost. The software required for CMRI as well on base computer system to use the remote reading feature with necessary security provisions shall also be supplied free of cost with following features:

- (i) The LPR should be able to read meter at a distance of minimum 100 Mtr. in open area without obstructions.
- (ii) The frequency range for LPR equipment shall be approved frequency range from the Govt. of India.
- (iii) The meter shall use license free frequency band for communication so that license for use LPR equipment to read energy meter at site is not required.
- (iv) It should not be possible to reset the energy reading in the meter with the CMRI.
- (v) The LPR module of the meter shall be completely enclosed in the meter body having no physical access from outside the meter without opening.
- (vi) The communication software must be capable to transfer the billing data and meter Sr No. required for automatic spot billing using any standard LPR module enabled spot billing machine (SBM), within 60 seconds, to automatically generate the energy consumption bills at consumer's premises without any human intervention after the data is collected from CMRI. The CMRI provided by meter manufacturer should continuously transmit the data until an acknowledgement is received from the SBM. The meter manufacturer should provide the protocol and other information to decipher the transmitted billing data and meter Sr No. for the spot billing purpose through SBM. The data communication with the meter shall be encrypted so that there is no possibility of tampering with the downloaded data.
- (vii) There should not be any degradation or interference on internal circuitry of meter because of LPR module.
- (viii) The compatibility of CMRI with the meter and the base computer system due to any change in language or any other reasons, the manufacturer/ supplier shall modify it at their own cost within guarantee period. The CMRI along with battery charger and for direct communication cords shall be supplied free of cost in the ratio of one for each 1000 Nos. meters supplied. The CMRI shall possess a specific Serial No. which cannot be changed.
- ix) The CMRI shall have facility to store 200 Nos. of meter data. Further, there should be a facility to be provided to transfer the meter data to computer through RS 232 / USB Port.

- x) The above mentioned all sorts of communication shall be of "One way" type i.e one can download the meter data through CMRI and data alteration facility in CMRI and from CMRI to meter should not be possible in any case.
- xi) The bidder has to give an undertaking that the CMRI supplied by them shall be capable for downloading reading of other make of meters in the instant tender as well as for next 5 years of any make of meters.

It shall be responsibility of the meter manufacturer to provide the required software and all the facilities required by JVVNL / AVVNL / JdVVNL to use the CMRI for reading and retrieving the data from the meter and to download the data to PC free of cost upto guarantee period.

Note: One No. CMRI capable for down loading the data through Optical Port and LPR along with connecting cable and its accessories as well as required connecting cable of 1.5 meter length for Optical Port to SBM for spot billing compatible to Optical Port of the meter and SBM, shall be supplied free of cost for every 1,000 Nos. meters supplied.

Readings to be downloaded with CMRI

In addition to all the above, the following parameters should be downloaded by CMRI through LPR.

- Meter Sr. No.
- Time & Date.
- Instant Load in KW, Voltage, Current & Power Factor
- Billing kWh (BP kWh) for the last **12** months at 0:00 hrs of the last day of the month.
- MD KW with 30 min. integration on real time basis for each phase with date and time stamp for the last **12** months.
- Average power factor of the last consumption month upto pre-defined date & time for the last **12** months.
- Power on Hours and minutes for each of previous **12** months
- The snap shot of each event with date & time of minimum 40 events(either occurrence or restoration consider an event) for following tamper condition:
 - (i) The tamper data as per Cl. 7.6 (c) & (g) of this specification
- Any other information if manufacturer proposes may indicate in their offer.

The meter shall also have a storage capacity for at least 60 days in the non-volatile memory for recording, logging, and downloading of Power On hours per day and kWh consumed for each day starting from 00.00 to 24.00 hours. Such data shall be made available in from or bar chart as well as spreadsheet. The BCS shall have the

facility to give complete load survey data both in numeric and graphic form with option for either of them.

The meter shall possess a suitable fast reliable LPR as well as Optical Communication Port for automatic transfer of data to CMRI and through CMRI to the base computer.

The CMRI shall possess easily replaceable battery and shall be capable of storing data for at least 200 Nos. meters at one time. It shall be possible to read the meter from outside the meter box. The data transfer (from meter to CMRI) rate of billing data downloading shall be 60 Seconds and for total data within 5 minutes for each meter.

The downloaded data along with date and time stamp of such reading shall remain on CMRI with suitable encryption and it shall not be possible to preprogram or manipulate the recorded data on the CMRI before downloading the same with the serial number of CMRI on computer. The CMRI shall also download the name of meter manufacturer and year and month of manufacture of meter. The Supplier shall supply Software (compatible with Windows 98 system or higher) and training free of cost for the use of software at multiple data collection and billing premises of the utility. The CMRI shall have a polling feature to read multiple meters within range without preprogramming the meter serial numbers on CMRI in advance.

After successful downloading of meters data to CMRI, the calibration LED shall continuously glow for a period of one minute/ any other indication on CMRI for confirmation of successful data transfer. During this period the energy recording should not be affected.

Necessary upgrades shall be possible in CMRI software and shall be supplied free of cost for downloading simultaneously the existing parameters and any parameters added in future specifications of meters. A copy of operation manual for each CMRI shall be supplied.

The Supplier shall provide meter reading protocols free of cost which shall not be complicated and easily understandable by utility officials to introduce compatibility between meters and CMRIs of different makes.

The bidder shall indicate relevant standard to which the protocol for communication between meter and CMRI shall comply.

In case of failure of power supply, it shall be possible to download the reading at least two times through a in-built battery.

7.6 Tamper and Fraud Protection

The meter should have tamper and fraud protection features so as to continue to register active energy correctly under the following conditions:

- a. Interchange of Main & Load: Correct energy registration even on interchange of one or more phases of main & load– the reverse indication in the form of blinking LCD phase icon or blinking phase LED to indicate which phase is reverse.

- b. Meter should remain functional even when either of any phases or any one phase along with neutral is available to the meter and record correct energy.
- c. The meter alone shall be immune to tamper using external magnet of the size 50mm.*50mm.*25mm. with a permanent magnetic field of 0.27 Tesla. The meter shall record energy at I max, rated voltage and unity power factor beyond meter's magnetic immunity level. However, the meter having magnetic immunity level more than 0.27 Tesla shall also be accepted and shall record energy at I_{max}., rated Voltage & Unity Power factor beyond their magnetic immunity level.

The meter shall be provided with built in logic/ indication and sensor to detect tamper beyond meter's magnetic immunity level and display such occurrences. The meter accuracy and accuracy of display shall not be affected by permanent magnetic field up to their meter's magnetic immunity level.

- d) The meter should work accurately irrespective of phase sequence of mains supply.
- e) The meter should record energy as per voltage measured between incoming phase and neutral terminals when DC signal is injected on the neutral terminal of the meter through Diode. The test in this condition will be carried out at V_{ref}. applied to incoming phase & input terminal of diode.
- f) The accuracy of the meter should not be affected with the application of abnormal voltage/frequency generating device having spark discharge of approximately 35 KV. The meter shall be tested by feeding the output of this device having Voltage discharge with 0-10 mm spark gap to meter in any of the following manner for the total period of 10 minutes:
 - i) On any of the phases or neutral terminals
 - ii) Spark on meter body .

The accuracy of meter shall be checked before and after the application of above device.

- g) **Cover Open Tamper** – If the meter cover is opened, the meter shall log this as tamper and shall display "Open" with date and time of such opening (in power on as well as power off condition) in blinking display on the LCD continuously with other display parameters so that it is immediately noticed by the meter reader.

The threshold values for different tamper features shall be as under:-
Occurrence time for logging of tamper shall be 5 minutes and restoration of tamper shall be less than 2 minutes.

7.7 Sealing Arrangement of the Meter :

a) The meter cover shall be permanently ultrasonically welded to the meter base. It shall not be possible to open the meter cover without permanently damaging the meter cover or base, easily visible from the front.

At least two unidirectional sealing screws of Nickel plated steel shall be provided for proper fixing of meter cover. Each unidirectional sealing screw shall have a independent sealing hole. **However better alternate arrangement other than unidirectional sealing screw for sealing arrangement shall also be accepted after approval of MM wing.** Manufacturer has to provide one polycarbonate seal on either side/front of the meter and two hologram sticker seals on both sides of meter with logo of JVVNL/manufacturer and the polycarbonate and sticker seals having the same number as that of the meter Sr. No. and one no. polycarbonate seal in loose condition to be provided on terminal cover of the meter. The manufacturer will also provide the software (25 Nos. or more) as per our requirement for tracking and recording of seals. **The Serial No. of Meter, Polycarbonate Body seal/ sticker seal & loose seal of terminal cover shall be same.**

7.8 Fixing Arrangement of Meter

The meter shall have minimum three fixing holes, one at the top for mounting and two at the bottom, inside the terminal cover. The top hole shall be key-hole type on the back of the meter base so that hanging screw is not accessible after fixing of the meter and it shall not be possible to remove the meter from the hanging screw without removing the terminal cover and screws behind the terminal block cover. The lower fixing hole/s shall be provided under the ETBC. Any alternate better arrangement shall also be considered for acceptance. All the fixing holes shall be such designed that once the meter is mounted; the screw heads shall not be accessible.

Manufacturer shall provide the appropriate fixing screws alongwith the meters.

7.9 Marking of Meter

The meter terminal marking and mounting arrangement should be as per Indian installation practices. The marking on every meter shall be in accordance with IS:13779/IEC 62052-11.

Every meter shall have name plate beneath the meter cover window portion such that the name plate cannot be accessed without opening the meter cover. The marking on the name plate shall be indelible, distinct and readable from outside the meter and meter box. The name plate marking should not fade or otherwise be adversely affected by UV exposure with lapse of time. The basic markings on the meter name plate shall be as follows.

- a. Manufacturer's name or trade mark and place of manufacture
- b. Designation of type
- c. Number of phases and wires for which the meter is suitable
- d. Serial number
- e. Month and year of manufacture
- f. Reference voltage and frequency.
- g. Basic current and rated maximum current in Amps

- h. Principal unit(s) of measurement
- i. Meter constant (imp/ kwh)
- j. Class index of meter
- k. "Property of JVVNL / AVVNL / JdVVNL"
- l. Purchaser's order Number & date
- m. Guarantee period- 5 Years
- n. Bar Coding of serial number, month & year of manufacture of the meter
- o. Sign of insulation
- p. Ultrasonic welded.
- q. ISI mark with license number.

7.10 Connection Diagram and Terminal Markings

The connection diagram of the meter shall be clearly shown on the name plate and shall be of permanent nature. Alternatively, connection diagram can be permanently engraved on the inside portion of terminal cover.

8.0 Salient Features

The meter shall have following additional salient features

- a. The meter shall be compact in design. The entire design and construction shall be capable of withstanding stresses likely to occur in actual service and rough handling during transportation. The meter shall be convenient to transport and immune to shock and vibration during transportation and handling.
- b. Even if phase to phase voltage i.e. 450 volts is applied for 5 minutes between phase and neutral of the meter, the meter should not get damaged and continue to record correctly within class 1 accuracy after restoration of normal supply.
- c. The meter should not saturate up to 800% I_b and should record energy accurately for P.F. range low power factor lag – unity – low power factor lead.
- d. The short-time over current rating shall be 30 I_{max} for one half cycle at rated frequency as per clause No. 9.2.3 of IS:13779/ IEC 26053-21 Clause 7.2.

- e. The meter should not have any form of mechanical adjustments such as trim-pots potentiometer etc. for calibration. The meter shall be tested, calibrated and sealed at manufacturer's works before dispatch. Further, no modification of calibration shall be possible at site by any means what so ever. The meter should be software calibrated.

All important data such as such as calibration data, billing parameters, and cumulative kWh should be stored in NVM internal to the main processing circuit and it should not be possible to change it through any standard serial communication. This may be verified by removing the non-volatile memory of the meter and check the working of the meter during sample testing or inspection.

- f. The meter shall be provided with CT/shunt in all the 3 phases. **The shunt used shall be high precision, low temperature coefficient, high stability of electric resistance, low watt loss and are magnetically tamper proof.**

The bidder shall use SMPS for Power Supply to PCB.

Specific confirmation shall be submitted by the bidders that accuracy of measurement will not suffer due to utilization of shunt on account of thermal variation and temperature coefficient up to an operational temperature of 80 deg C.

Specific confirmation shall be submitted by the bidders that accuracy of measurement will not suffer due to utilization of shunt on account of thermal variation and temperature coefficient up to an operational temperature of 80 deg.c.

- g. LEDs shall be provided for following indications
- 1) Test output pulse – Red (imp/kwh)
 - 2) Indication for healthy PT/Voltage supply for each phase Red-Yellow-Green

LEDs can be alternatively provided as icons on the LCD display.

The location of calibration LED (preferably at the center) should be such that the calibration pulses can be sensed easily through the sensor.

- h. Each new supplied lot shall be tested on automatic test bench of 0.02 class accuracy in meter lab, the meters having accuracy results within +/- 0.5% shall be preferred.

- i. Temperature rise – Under normal conditions of use at I_{max}. current and 1.2 times rated voltage, the winding and insulation shall not reach a temperature, which might adversely affect the operation of these LT Meters.
- j. Specific confirmation shall be submitted by the bidders that accuracy of measurement will not suffer due to utilization of shunt on account of thermal variation and temperature coefficient upto an operational temperature of 80 Deg.C.
- k. **The communication software must be capable to transfer cumulative active energy with date and time and meter Sr.No. required for automatic spot billing using any standard optical enabled spot billing machine (SBM), within 60 seconds, to automatically generate the energy consumption bills at consumer's premises without any human intervention after the data is collected from CMRI. The CMRI should continuously transmit the data until an acknowledgement is received from the SBM. The successful bidders should provide the protocol and other information to decipher the transmitted billing data and meter Sr.No. for the spot billing purpose through SBM. The data communication with the meter shall be encrypted so that there is no possibility of tampering with the downloaded data.**
- l. **The meter shall display total energy on display and record fundamental & Total Energy (Fundamental + harmonics) at BCS end.**
- m. **The push button on meter cover & meter box cover should be designed such that it is not possible to remove / take out the push button by any means. There should not be any gap between push button & cover so that any possibility by fiddling any sharp object or needle from outside of the meter or meter box around push button is not possible.**

9.0 General

- a. All electrically live screws shall be of brass/ nickel tin plated. All other screws shall be electro plated.
- b. The meter shall draw its power from all three phases, one phase and neutral or any two phases
- c. The terminal inserts shall be of heavily tinned brass and shall be replaceable type.
- d. The meter shall conform to the degree of protection IP 51 of IS:12063/IEC.60529 and IEC 62052-11 clause 5.9, for protection against ingress of dust, moisture and vermin
- e. There should not be any creepage in the meter even at 120% & 70 % of supply voltage.

- f. The meter should be free from jumps during sudden switching of heavy loads / or transient voltage spikes

Meter shall display direct reading and without multiplying factor

10. **Electromagnetic Compatibility and Interference requirement**

The meter shall meet EMI/EMC requirements as specified in the relevant standards described in clause 3.0 of this specification and shall also be protected against radiated interference from either magnetic or radio frequency sources.

The offered whole current meter shall also withstand DC Immunity test as per relevant standard so as to ensure that the meter current circuits do not saturate on passage of direct current.

The meter shall be designed in such a way that the conducted or radiated electromagnetic disturbance as well as electrostatic discharge do not damage or substantially influence the meter.

The disturbance(s) to be considered are:

- a. Harmonics
- b. Voltage dips and short interruptions
- c. Fast transient burst test
- d. External D.C. and A.C. magnetic fields
- e. Electromagnetic H.F. fields
- f. Electrostatic discharges
- g. Radio frequency interference suppression

11. **Manufacturing Activities**

All the materials, electronics and power components, ICs used in the manufacture of the meter shall be of highest quality and reputed make (as per Annexure-A-3) to ensure higher reliability, longer life and sustained accuracy. However, components of other reputed make also acceptable after prior approval of Purchaser. The verification of the components shall be carried out at manufacturer's works by purchaser before offering material for inspection for every lot. The supplier is required to intimate purchaser whenever any lot is taken up for manufacturing/ assembly. The Purchaser reserve the right to waive off the verification of manufacturing activity.

- a. The manufacturer should use application specific integrated circuit (ASIC) or Micro controller for metering functions.
- b. The electronic components shall be mounted on the printed circuit board using latest surface mounted technology (SMT) except power components by deploying automatic SMT pick and place machine and re-flow solder process. No wave soldering or solder bath will be used.

The electronic components used in the meter shall be of high quality and there shall be no drift in the accuracy of the meter at least upto 10 years. Further, the Bidder should own or have exclusive access (through hire, lease or sub-contract) of the afore-mentioned facilities.

Adequate documents regarding exclusive hire or exclusive lease shall be made available. In case of sub-contract, it shall be ensured that the sub-contractor is not carrying out sub-contracting for any other bidder in the above tender. The bidder shall indicate with the name and location of such facility alongwith an undertaking and certificate from the utility and any ambiguity on such a confirmation shall result in immediate disqualification of the bidder.

The above shall be verified during works inspection or material inspection also and if any ambiguity is found, it shall be considered as a breach of contract by the successful bidder.

Bidders without in-house design, development and manufacturing facility as above or who are buying populated PCBs will not be considered as meter manufacturers.

The PCB material should be of glass epoxy FR-4 grade conforming to relevant standards.

- c. All insulating materials used in the construction of meters shall be non-hygroscopic, non-aging and of tested quality. All parts which are likely to develop corrosion shall be effectively protected against corrosion by providing suitable protective coating.

- d. Quality should be ensured at the following stages
 - a. At PCB manufacturing stage, each board shall be subjected to bare board testing
 - b. At insertion stage, all components should undergo testing for conforming to design parameters and orientation
 - c. Complete assembled and soldered PCB should undergo functional testing using test equipments (testing jig).
 - d. Prior to final testing and calibration, all meters shall be subjected to accelerated ageing test to eliminate infant mortality.
- e. The calibration of meters shall be done in-house.
- f. The bidder should submit the list of all components used in the meter along with the bid.
- g. A detailed list of bought-out items which are used in the manufacture of the meter should be furnished indicating the name of firms from whom these items are procured. The bidder shall also give the details of quality assurance procedures followed by him in respect of the bought – out items
- h. The details of testing facilities available for conducting the routine and acceptance tests and other special tests on the meter shall be furnished with the bid. The facility available if any for conducting type test may also be furnished.

The components of the meters shall be as per specification (Annexure-'B')

12. Type Test

- a. The type test certificates for all tests as per IS:13779-1999/relevant IEC standard (latest amendments) and under mentioned additional type tests shall be furnished along with tender. The Type test certificates from any one of the standard laboratories such as NPL /ERTL / CPRI /ERDA (NABL accredited for particular equipment/ test) and conducted at government approved lab shall only be considered valid.
- b. Type test certificates from educational institute(s) will not be accepted. The type test certificates shall not be more than 24 months old from the date of bid opening.
- c. The type test reports shall be submitted along with the bid or within 30 days of opening of technical bid. In case type tests reports are not received within 30 days from the date of opening of technical bid, the offer of the bidder shall be considered as non-responsive.

d) Verification of testing of materials supplied

i) After receipt of approval of before commencement sample meters with seals, the successful bidder shall offer first lot of meters comprising minimum 5,000 nos. of meters (or 20% of ordered quantity, or ordered quantity, whichever is less) for inspection within 30 days. After satisfactory testing & clearance from purchaser, the material shall be despatched to Nigam's stores.

ii) **Three samples for type tests including MIL test and additional type tests shall be selected from any one of three Discom** & sealed by a Committee consisting of circle SE, XEn (O&M) and ACOS from the first lot received in Nigam's stores. The samples so selected shall be sealed by at least 3-4 seals/ stickers by the Committee Members. The selected samples shall be sent to SE(MM) along with complete details of meters & seals (including manufacturer's seals) provided by the Committee members. The SE(MM) shall further send the meters with complete details for type tests and additional type tests/ special tests/ tamper tests as per specification at any NABL accredited test lab. The complete type test report under a cover of registered letter shall be sent directly to the purchaser. In addition to above three sample of meters along with 6 Kg. raw material each for meter case and terminal block shall be selected & sealed by the aforesaid procedure and shall be sent to CIPET/ any NABL accredited test house for verification of properties of plastic material of meter case (base & cover) & Terminal Block as mentioned at clause 7.1 & 7.2 of specification. The type test charges shall be borne by the supplier. The purchaser however in first instance may pay testing charges to the testing agency which shall be recovered by AO(CPC) from the bill of the supplier alternatively a sum of Rs. 2 Lac may be got deposited by the supplier with first inspection call.

iii) The supplies, at the option of purchaser, may be utilized in the field after successful testing of sample meters in respect of the tests as mentioned at clause 12.0 (d) (vi) below, at purchaser's MT lab. The supplier can continue supplying material in anticipation of successful type test(s) results. 70% of the payment shall be released after receipt of successful purchaser's MT lab tests report and balance payment shall be released after receipt of successful type test reports.

iv) In case of successful type test results, supplies shall be continued. However, in case the meter(s) do not meet the requirement as per ISS/CBIP/ Specification in type test(s), three more samples shall be selected from the supplies already received to get them type tested as per clause 12 (d) (ii) above at supplier's cost. In case of repeat failure in type test(s), the order of balance quantity including the quantity lying unused in the stores/ field shall be cancelled. The guarantee period of quantity already supplied & used shall be doubled and payment for used meters shall be arranged after deducting 10% cost.

The above type tests shall be carried out on samples selected from first lot received in store of any one of three Discoms and type tests report shall be considered for all three Discoms i.e. JVVNL, AVVNL & JdVVNL.

v) However, purchaser may allow the supplier to re-offer the material after change/ modification in the design of meters. The balance material shall be accepted only after successful type testing. The type testing charges shall be borne by the supplier.

vi) Besides above type tests, samples from each lot/ sub-lot shall be selected and subjected to the following test(s) at purchaser's lab. The samples shall be as per sampling plan indicated at Annexure-H of IS:13779/1999 (considering lot of 10,000 Nos. meters) if quantity offered for inspection is 20,000 Nos. or more , if less than this, the lot shall remain 5,000 Nos.) on pro-rata basis. The samples shall be selected & sealed by a committee consisting of circle SE, XEn(O&M) & ACOS. The samples so selected shall be sealed by seals/ stickers by the committee members put in the primary packing of the meter and box (which shall be sealed by sticker seals) and then all the meters selected to be put in the primary packing corrugated box supplied with the meters and again sealed by sticker seals by the committee members. The selected samples shall be sent to SE(M&P), Jaipur along with complete details of meters & seals provided by the Committee members. the sealed and packed boxes shall be opened and witnessed by the firm's representative at the time of testing of such meters. The supplies shall be utilized in the field only after successful testing (in respect of under mentioned tests) of sample meters :-

S. No.	Particulars of Tests	No. of samples to be tested
1.	Starting Current Test and No Load Test.	32 Nos.
2	A.C. High Voltage Test, Limits of error, test of meter constant & Power consumption test for voltage and current circuits.	8 Nos. out of above 32 Nos.
3.	Repeatability of error.	3 Nos. out of above 8 Nos.
4.	Voltage Variation, Tamper & fraud protection, D.C. Component in A.C. Circuit for each phase circuits), Magnetic Immunity Test (Permanent magnet test of 0.27/0.5 Tesla), Accuracy test after application of 450 Volts for 5 minutes, D.C. Injection at neutral using diode, Saturation test as per clause 8.0 (c) and high voltage / high frequency generating spark etc.test of specification.	3 Nos. out of above 8 Nos. subjected to the condition that all the 8 meters pass the tests at S.No. 2 above successfully otherwise whole lot shall be considered rejected without going for further testing.

The acceptability criteria of the lot or otherwise shall be generally as per relevant ISS :13779-99 (latest amended) for only the tests at at Sr. No. 1, 2 & 3 above.

vii) In case of failure of samples of lot/ sub-lot in the test(s) detailed at clause No. (vi) above, the similar testing shall be repeated on fresh samples selected by the committee & fresh testing as mentioned at 1 to 4 above shall be carried out. If the samples meet the requirement of above tests, the lot shall be accepted and if it fails consecutive second time, the entire quantity of respective lot/sub-lot shall be rejected and shall have to be replaced by the supplier at his own cost. Repeated failure/ poor results in the testing may render cancellation of order.

viii) Due notice shall be given to supplier for testing thereof to enable them to be present for the same if so desired by them. If the supplier or his authorized representative fails to attend the sample testing, the same shall be carried out unilaterally by the purchaser and the results thereof shall be binding upon the supplier.

ix) The purchaser also reserves the right to get additional samples for all or any of the selected tests at purchaser's cost at any independent test house at any stage of supply if so considered necessary to ensure that the quality of meters being offered for inspection is same as already got type tested. In case of failure, the guarantee period of the quantity already supplied by the supplier shall be doubled and purchaser reserve the right to cancel the balance quantity.

13. GUARANTEED TECHNICAL PARTICULARS

The bidder shall furnish all the necessary information as desired in the schedule of Guaranteed Technical Particulars and data, appended at Annexure-'B' & 'C' of this specification. If the bidder desire to furnish any other information(s) in addition to the details as asked for, the same may be furnished against the last item of this Annexure.

14. **Inspection and Testing**

- a In case material/equipment is not found ready in good / acceptable condition by the representative(s) of the purchaser deputed for inspection to the extent of the quantity indicated in the inspection call with tolerance of (-) 10% or if the inspection is not got carried out by any reasons on account of the supplier an amount of Rs.3,000/- for the supplier's works located in Rajasthan, and an amount of Rs.10,000/- for the supplier's works located outside Rajasthan will become payable by the supplier on this account to the Accounts Officer (MM) Jaipur Discom, Jaipur.
- b All Acceptance tests as laid down in the ISS/IEC and this tender specification shall be carried out. The supplier shall provide all routine test reports for entire offered quantity of energy meters in CD to the inspecting officers
- c Following tests shall also be carried out as Acceptance tests by adopting methods specified in ISS:13779/IS:9000/relevant IEC standard/ CBIP 304.

- a. AC voltage test
- b. Test of meter constant
- c. Tests of limits of error as per cl. 11.11 of IS 13779 at 400%Ib, 600% Ib and 800 % Ib at pf 0.5 lag, 0.8 lead & unity.
- d. Vibration test
- e. Shock test

Vibration & shock test shall be carried out as acceptance test by adopting procedure laid down in ISS: 13010/1990/IS-9000 and its latest amendments.

- f. Test of Voltage variation as per this specification.
- g. Test of no load condition at 70% and 120 % of rated voltage. The minimum test period shall be as per Clause 8.3.2 of IEC : 62053 – 21-2003.
- h. Test of DC components in AC circuits - The limit of variation in percentage error shall be 3.0% for class 1.0 meter as per Annex-D of IS: 13779 for each phase circuit.
- i. Diode test
- j. Accuracy tests under all anti tamper conditions, clause 7.6 of this specification.
- k. Permanent magnet test (as specified in Clause 7.6(d) of this specification)

- l. The inspecting officer shall verify that no DC supply/ signal is given to reference meter during the DC injection test.
 - m. Display parameters shall be verified at the time of inspection.
 - n. Test of application of abnormal voltage/frequency generating devices (electronic gadgets) as per this specification.
 - o. When the meter is placed in oven at a constant temperature of 65° C for period of 120 minutes, the character of LCD should not deform. After keeping the meter at a constant temperature of 80 ° C for period of 120 minutes and when restored at normal temperature, the LCD should work satisfactorily.
- p. Verification of continuous ultrasonic welding.
- d) Number of samples for test from each lot shall be selected as per provision of IS. The criteria for selection of No. of samples and for acceptance of lot will be as under.

S.No	Particular of tests	Sampling plan for the lot of 1001 and above	Criteria for acceptance of lot
1	HV. A.C. test & I.R. test. No load test and minimum starting current test	32 nos.	As per clause C-3.1 of ISS
2.	All other acceptance tests as per cl. 149b) above , vibration test and shock test in sequence to be mutually agreed between manufacturer and inspecting officer.	8 nos out of above 32 samples passing tests at s. no. 1.	As per clause C-3.2 of ISS Annex.C
3.	Repeatability of error test, vibration test and shock test, in sequence.	3 Nos. out of above 8 samples passing tests at S.No. 2	Each sample should pass all three tests.

The sampling plan shall be as per IS:13779 except that maximum lot size may be read as 10,000 Nos. meters in place of 5,000 Nos. meters only for minimum offered quantity of 20,000 Nos. for Inspection otherwise the maximum lot size shall remain 5,000 Nos. meters. The sub-lot size shall be taken accordingly i.e. either 5,000 Nos. or 10,000 Nos. as applicable.

32 Samples shall be selected at random from the each sub lot of meters and acceptance test as per relevant standards and additional acceptance tests as per technical specification shall be carried out on these samples.

15.0 Packing and forwarding of Energy Meters:

Each meter shall be packed in superior quality three ply corrugated cardboard carton or thermocol packing box. Such single cartons shall be additionally packed in five (5) ply corrugated cardboard carton accommodating 12-24 meters with meter boxes for easy transportation, storage & handling.

16.0 Samples:**a) Samples along with bid**

Four meters conforming to this specification duly sealed along with the routine test certificates shall be furnished with the bid. If the samples are not received with the bid, the bid shall be considered as Non-responsive. Out of the above four sample meters, three sample meters shall be tested at any NABL accredited independent test lab in presence of firm's representative. The testing charges shall be borne by the bidder. One sample meter shall be checked/tested for mechanical/physical features in Nigam's Lab. In case sample meters submitted with bid don't conform the type tests, Additional type tests & tamper tests as per the requirements of specifications/IS, the financial bid of offer shall not be opened.

Additional type tests and Tamper Tests to be conducted on bid stage samples are as under:

- i) DC influence test as per IS:13779-1999 or as per relevant IEC standard in phase circuit(s).
- ii) The test of influence of supply voltage shall be carried out as per clause No.12.7.2.1 of IS:13779/1999, except the interruption time should be variable from 10 ms to 5 sec. instead of fixed time.
- iii) Test of voltage variation as per this specification.

b) Sample before Commencement of supplies:

The supplier shall furnish to any one of three Discom duly sealed three sample meters having all the features confirming to this specification **within one month from the date of LOI, for testing in NIGAM'S Lab for approval before commencement of supply.**

c) The samples furnished by bidders at various stages of tender and the samples selected for store testing shall be tested on automatic testing bench, which has accuracy of 0.02.

17.0 Replacement of Defective Meters:

The meters declared defective by the consignees and /or by meter testing lab shall be replaced by the supplier up to the full satisfaction of the purchaser at the cost of supplier as per clause no. 1.18 of GCC within one month of intimation by purchaser/stores officer.

18.0 Maintenance & Guarantee:

a) It shall be governed by Clause 1.40 of GCC except that the guarantee shall be for a period of 5 years from the date of dispatch. The bidder shall replace the defective meters at the purchaser's stores within a period of 45 days from the date of intimation (from the concerned ACOS) of failure. In case defective meters are not replaced in stipulated period the penalty as per clause of delay in delivery shall be applicable.

The meter will be declared defective within guarantee period after testing in the meter testing lab.

b) If the performance period of the supplied material is over and some quantity of guarantee period defective meters are still lying pending for want of repair / replacement than fresh Bank Guarantee equal to the cost of these guarantee period defective meters may be accepted by Nigam and original PBG shall be released.

19.0 Quality Assurance Plan:

The design life of the meter shall be minimum 20 years and to prove the design life, the firm shall have at least the following quality Assurance Plan:-

- (i) The factory shall be completely dust proof.
- (ii) The testing rooms shall be temperature and humidity controlled as per relevant standards.
- (iii) The testing and calibrating equipments should be automatic and all test equipment shall have their valid calibration certificates.
- (iv) Power supplies used in testing equipment shall be distortion free with sinusoidal wave- forms and maintaining constant voltage current and frequency as per the relevant standards.
- (v) During the manufacturing of the meters the following checks shall be carried out.
 - a) Meter frame dimensions tolerance shall be minimum.
 - b) The assembly of parts shall be done with the help of jigs and fixtures so that human errors are eliminated.
 - c) The meters shall be batch tested on automatic, computerized test bench and the results shall be printed directly without any human errors.
- vi) The bidder shall invariably furnish the following information alongwith his bid, failing which his bid shall be liable for rejection. The information shall be separately given for individual type of material offered.
 - a) Statement giving list of important raw materials, names of sub-suppliers for the raw materials, list of standards according to which the raw

- materials are tested, list of tests normally carried out on raw material in presence of bidder's representative and copies of test certificates.
- b) Information and copies of test certificates as in (i) above in respect of bought out accessories.
 - c) List of manufacturing facilities available.
 - d) Level of automation achieved and list of areas where manual processing exists.
 - e) List of areas in manufacturing process, where stage inspections are normally carried out for quality control and details of such tests and inspections.
 - f) List of testing equipment available with the bidder for final testing of equipment specified and test-plant limitations, if any, vis-a-vis the type, special acceptance and routine tests specified in the relevant standards and this specification. These limitations shall be very clearly brought out in schedule of deviations provided with the tender.

20.0 Accuracy of Meters:

The supplier shall furnish written undertaking on Rs. 100.00 Non Judicial Rajasthan Govt. Stamp paper that there will be no drift in the accuracy of the meters supplied against this purchase order for a period of 10 years from the date of supply. In case any drift is noticed/found beyond permissible limits during this period, they shall recalibrate such a meter for correct accuracy, and in the event recalibration is not possible, replace such meter(s) with new meter(s) without any extra cost.

21.0 Qualification Requirements

The qualification requirements shall be as per Schedule-III A.

22.0 Prices:

Tenderer must quote 'FIRM' prices. The quoted prices shall be exclusive of Excise Duty and Central/State Sales tax. If no duty and/ or tax is applicable at concessional rate, the same shall be clearly mentioned.

23.0 Delivery

The bidder is required to quote monthly delivery. The delivery of quoted quantity should be completed in 10 months period including commencement period of 30 days. In case ordered quantity is different than quoted quantity then monthly delivery shall be adjusted proportionately. Tenders in which monthly delivery schedule is not indicated shall be ignored.

24.0 General Information

- a) Frequent changes in specifications during currency of contract will be avoided and if required the same shall be effected on mutually agreed basis.
- b) Nigam is not averse to deciding tenders on differential prices to get better quality meters.

ANNEXURE-A

COMPONENT SPECIFICATION

S. No.	Component	Requirement	Makes & Origin
1.	Current Element	E-beam/spot welded shunts shall be provided in the phase element and C.T. in the neutral. Alternatively, both the current elements (phase & neutral) shall have shunts with proper insulation. The	Any make or origin conforming to IS-2705 and other make i.e. Redbourn Engg/ Isabelle.

		meters should be with the current transformers / shunt as measuring elements.	
2.	Measurement of computing chips.	The measurement or computing chips used in the meter should be with the surface mount type along with the ASICs.	Analog Devices, Cyrus Logic, AMS, Atmel, Phillips. SAMES, NEC, Texas Instruments
3.	Memory Chips.	The memory chips should not be affected by the external parameters like sparking, high voltage spikes or electrostatic discharges.	Atmel, National Semiconductors, Microchip, Texas Instruments, Phillips, ST Hitachi or Oki, Teridian
4.	Display modules	a) The display modules should be well protected from the external UV radiations. b) The construction of the modules should be such that the displayed quantity should not disturbed with the life of display. c) The display should be clearly visible over an angle of at least a cone of 70°. c) It should be trans-reflective FSTN or STN Type industrial grade with extended temperature range.	Genda, Haijing, Holtek, Bonafied Technologies Korea : Advantek, Truly Semiconductor Success Hitachi, Sony.
5.	Electronic Components.	The active & passive components should be of the surface mount type and are to be handled & soldered by the state of art assembly processes.	National Semiconductors, Atmel, Phillips, Texas Instruments, Toshiba, Fairchild, Murata, Rohm, Siemens. Hitachi, Oki, AVX or Ricoh. Samsung.
6.	Battery	Lithium with minimum guaranteed life of 15 years.	Varta, Tedirun, Sanyo or National, Durocell
7.	RTC & Micro Controller.	The accuracy of RTC shall be as per relevant IEC / IS Standards.	Phillips, Dallas Atmel, Motorola, Microchip. NEC or Oki.
8.	P.C.B.	Glass Epoxy, fire resistance grade FR4, with minimum thickness 1.6 mm.	-
9.	Communication modules	Communication modules should be compatible for the RS232 ports	National Semiconductors, Hitachi, Texas Instruments, Philips, HP, Agilent

10.	Optical port	Optical port should be used to transfer the meter data to meter reading instrument. The mechanical construction of the port should be such to facilitate the data transfer easily.	National Semiconductors, Hitachi, Texas Instruments, Siemens, Agilent, Philips, Hp
11.	Power supply	The power supply should be with the capabilities as per the relevant standards. The power supply unit of the meter should not be affected incase the maximum voltage of the system appears to the terminals due to faults or due to wrong connections.	
12	Mechanical parts	The internal electrical components should be of electrolytic copper & should be protected from corrosion, rust etc. The other mechanical components should be protected from rust, corrosion etc. by suitable plating/painting methods.	-

GUARANTEED TECHNICAL PARTICULARS OF THREE PHASE STATIC ENERGY METERS OF RATING 10-60A WITH LCD BACK-LIT DISPLAY.

SN.	Particulars	TO BE FURNISHED BY BIDDER
1.	Name & Address of Manufacturer	
2.	Work's Address	
3	Type / Designation of meter offered	
4	Class of Accuracy	
5	Standard Applicable	
6	Type of Meter (no. of phases & wire / elements)	
7	Rating and General Particulars	
	a) Reference Voltage	
	b) Basic current (I_b)	
	c) Maximum current (I_{max})	
	d) Maximum withstand current (i.e.150% of I_{max})	
	e) Voltage with stand 450V for 5 minutes	
	f) Power supply variation (-40% to +20% V_{ref})	
8	Whether meter is suitable for working with following supply system	
	i) Specified operating range	
	ii) Limit range of operation	
	iii) Frequency	
	iv) Power factor range	
	v) Ambient temperature range	
9	Insulation resistance between:	
	a) Meter current circuit and voltage circuit	
	b) Current and voltage circuit coupled and all non-current carrying parts connected together	
10	Min. starting current per phase (in Amps)	

GUARANTEED TECHNICAL PARTICULARS OF THREE PHASE STATIC ENERGY METERS OF RATING 10-60A WITH LCD BACK-LIT DISPLAY.

SN.	Particulars	TO BE FURNISHED BY BIDDER
11	Details of meter fixing arrangements: Is the meter fixing arrangement with the base of meter box is as per the provision of this specification?	
12	A) Detail of sealing arrangement: i) No. of Tamper proof transparent polycarbonate security seals provided on meter body and its colour /details of other sealing arrangement. ii) The monogram of JVVNL is laser etched printing / embossed on front side and month & year of manufacturer. iii) The Sr No on the seals is same as meter Sr No? iv) Is the Sr No. on seals is laser etched/ embossed? B) Whether base and cover are permanently fixed to the base by heat stacking / ultrasonically welding as per Clause 7.1(e) of Spec. C) Whether seals are visible from front side of meter?	
13.	Details of meter base and cover a) Degree of protection of meter case? (Whether Type Test Certificate enclosed) b) Thickness and material of Meter base and cover c) Whether cover is transparent	
14	Details of terminals block and its cover a) Whether Material of terminal block used, conforms to clause 7.2.1 of this specification? b) Thickness and material of Terminal cover c) Minimum center to center distance between adjacent terminals d) Details of screws provided on each terminal for fixing aluminum / copper stranded wires (no. & dimensions)	

GUARANTEED TECHNICAL PARTICULARS OF THREE PHASE STATIC ENERGY METERS OF RATING 10-60A WITH LCD BACK-LIT DISPLAY.

SN.	Particulars	TO BE FURNISHED BY BIDDER
	e) i) Minimum internal diameter of terminal holes?	
	ii) Is it adequately designed to accommodate copper / aluminium armoured PVC cable of size up to 6 sq mm to 25 sq. mm	
	f) Whether terminal cover is of extended type. Please give extended length of terminal cover below terminal block.	
15	Whether voltage & current circuits are solidly connected inside the meter body without any link?	
16	Whether window portion is as per specification?	
17	Details of CT's / Shunts provided	
	a) CT(s)/ Shunt(s) provided in phase	
	b) Size of secondary wire of CT / Size of Shunt(s) used	
	c) No. of turns of secondary winding of CT	
	d) Whether CTs and Shunts have been properly fixed on base/PCB/ current terminals?	
18	Whether components on the PCB are surface mounted except power components?	
19	Whether PCB material is glass epoxy FR-4 grade?	
20.	Whether all parts that are likely to develop corrosion effectively protected against corrosion?	
21	Whether the name plate provided on meter bears the following information in addition to marking required as per specification:	
	i) Manufacturer's name or trade mark and place of manufacturer	
	ii) Designation of type	
	iii) Number of phases and wires for which the meter is suitable	
	iv) Serial Number	
	v) Month and year of manufacture	
	vi) Reference voltage and frequency	
	vii) Principal unit(s) of measurement	

GUARANTEED TECHNICAL PARTICULARS OF THREE PHASE STATIC ENERGY METERS OF RATING 10-60A WITH LCD BACK-LIT DISPLAY.

SN.	Particulars		TO BE FURNISHED BY BIDDER
	viii)	Basic current and rated maximum current in Amps	
	ix)	Meter constant (Imp/kWh)	
	x)	Accuracy class	
	xi)	Property of JVVNL/AVVNL/JdVVNL	
	xii)	Purchase Order Number and Date	
	xiii)	Guarantee period	
	xiv)	The sign of insulation	
	xv)	Bar coding of Sr. No., month & year of manufacture of meter.	
	xvi)	Ultrasonic welded	
	xvii)	ISI mark with license number	
22	Power consumption of voltage circuit per phase (Watt & VA)		
23	Power consumption of current circuit (VA)		
24	Overall dimension of the meter with \pm % tolerance		
25	Weight of the meter with \pm % tolerance		
26	Does meter has Short time over current withstand capability of 30 I _{max} for one half cycle at reference frequency?		
27	Does the meter comply with Impulse voltage withstand capacity of 6kV?		
28	a)	Does the meter have any type of mechanical adjustment (trim-pots, potentiometer etc) for calibration?	
	b)	Are the meters software calibrated? (Yes/No)	
29	A) Display sequence		
	a)	Continuous display: Current cumulative active forwarded energy (Total Energy) with one decimal size of digit minimum 10x5 mm(without decimal) shall be continuously displayed.	
	b)	Push Button display:	

GUARANTEED TECHNICAL PARTICULARS OF THREE PHASE STATIC ENERGY METERS OF RATING 10-60A WITH LCD BACK-LIT DISPLAY.

SN.	Particulars	TO BE FURNISHED BY BIDDER
	1. LCD Segment Check. 2. S.No. of Meter. 3. Date and Time	
	4. Current cumulative active forward energy (Total) with one decimal.	
	5. Cumulative active energy (KWh forwarded) reading of pre-defined date & time of previous month for Billing purpose(BP kWh), 6 whole digits.	
	6. Maximum demand(KW) of pre-defined date & time of previous month for billing purpose (BP KW), 2 whole digits plus 2 decimal digits.	
	7. Average power factor up to pre-defined date & time of previous month for billing purpose(BP Ave PF), one whole digit plus 3 decimal digits.	
	8. Instantaneous active load in KW with three decimals.	
	9. Instantaneous Voltage per phase with one decimal.	
	10. Instantaneous current per phase with two decimals.	
	11. Signed Instantaneous Avg. Power factor with three decimals.	

GUARANTEED TECHNICAL PARTICULARS OF THREE PHASE STATIC ENERGY METERS OF RATING 10-60A WITH LCD BACK-LIT DISPLAY.

SN.	Particulars		TO BE FURNISHED BY BIDDER
30	Display details		
	a)	Type of Display, minimum character height & no. of Digits	
	b)	Is the display having back lit?	
	c)	Does display have one decimal digit for cumulative Active Energy KWh in Auto Scroll Mode?	
	d)	Is NVM having min retention time of 12 years provided?	
	e)	Accuracy of RTC (minutes/year)?	
	f)	Internal Least count of energy recording?	
	g)	Provision to read the Meter two times in no Power condition is provided with inbuilt Battery for taking Meter reading in Power-Off condition.	
		With primary / rechargeable battery for taking meter reading in power-off condition.	
		Is the above provision capable of 50,000 such operation during the meter life time of 15 years	
31.	For communication capability		
	A	i) Whether it is possible to read the meter through LPR communication/ optical communication port facility as per clause 7.5 of spec.	
		ii) Whether CMRI have facility to store 200 nos. of meter data	
		iii) Whether the following parameters can be downloaded by CMRI	
		a) Meter Sr. Mo.	
		b) Time and date	
		c) Instant load in KW, voltage, current and power factor	
		d) Billing kWh (BP kWh) for the last 12 months	

GUARANTEED TECHNICAL PARTICULARS OF THREE PHASE STATIC ENERGY METERS OF RATING 10-60A WITH LCD BACK-LIT DISPLAY.

SN.	Particulars		TO BE FURNISHED BY BIDDER
		e) MD KW with 30 min integration on real time basis with date and time stamp for the last 12 months f) Average power factor of the last consumption month upto pre-defined date and time for the last 12 months g) The tamper data as per Cl. 7.6 (c)&(g) h) Power-On hours and minutes for each of previous 12 months i) The snap shot of occurrence with date & time of minimum 40 events as per Clause 7.6(c) & (g) of specification.	
	iii)	Whether total reading time for each meter does not exceed more than 60 seconds for billing data & 5 minutes for complete data.	
32.	Whether indications provided for following:		
	a)	Red, Yellow, Blue LED for test output pulse (Imp/kWh)	
	b)	LCD icon for healthy RYB phases	
33	a)	Year since when the design offered is in vogue	
	b)	Whether the offered design is completely type tested and certified by BIS	
34.	a)	Please confirm that meter does not get damaged even if 450V is applied for 5 minutes between phase and neutral and continue to record correctly after restoration of normal supply?	
	b)	Whether meter perform within class 1.0 accuracy up to 800% I_b for power factor range 0.5 lagging, 0.8 leading & unity?	
	c)	Whether meter remains functional and is capable to record energy even if voltage falls up to 60% of rated voltage at I_b to I_{max} .	

GUARANTEED TECHNICAL PARTICULARS OF THREE PHASE STATIC ENERGY METERS OF RATING 10-60A WITH LCD BACK-LIT DISPLAY.

SN.	Particulars	TO BE FURNISHED BY BIDDER						
35.	Indicate guaranteed accuracy of meters at different ranges of voltages / P.F.							
36	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td data-bbox="402 394 516 436">Influence quantity</td> <td data-bbox="516 394 683 436">Current P.F.</td> <td data-bbox="683 394 878 436">Limits of variation of % error</td> </tr> <tr> <td data-bbox="402 436 516 667">a)</td> <td data-bbox="516 436 683 667">Voltage variation between - 40% to + 20%</td> <td data-bbox="683 436 878 667">I_b unit y I_b 0.5 lag</td> </tr> </table>	Influence quantity	Current P.F.	Limits of variation of % error	a)	Voltage variation between - 40% to + 20%	I _b unit y I _b 0.5 lag	
Influence quantity	Current P.F.	Limits of variation of % error						
a)	Voltage variation between - 40% to + 20%	I _b unit y I _b 0.5 lag						
37	Whether meter is packed in corrugated Box / Thermocol packing boxes as per specification							
38.	Does the meter comply to running with no load of 70% and 120% of rated voltage - as per this specification?							
39.	Mention the value up to which meter can withstand Direct Current in A.C. circuit without getting CT's saturated resulting in measurement errors of more than permissible limit							
40.	Does meter meets the Magnetic Immunity Levels of A.C. and D.C. magnets filed prescribed in CBIP Technical report 304 with latest amendments and permanent magnet of 0.27 Tesla, as per specification							
41	Does the bidder own the facilities of SMT manufacturing or have access thru' hire, lease or sub-contract the facilities?							
42	Does the bidder have exclusive access to these facilities and have furnished adequate documents as proof?							
43	Does the bidder have in-house design, development and manufacturing facilities?							

GUARANTEED TECHNICAL PARTICULARS OF THREE PHASE STATIC ENERGY METERS OF RATING 10-60A WITH LCD BACK-LIT DISPLAY.

SN.	Particulars	TO BE FURNISHED BY BIDDER
44	Cover open tamper occurred with date & time.	
45	The communication software must be capable to transfer the billing data and meter Sr.No. required for automatic spot billing using any standard optical/LPR Port enabled spot billing machine (SBM), within 60 seconds	
